

Proudly Distributed By

TURBINE FLOWMETERS BY HOFFER Perfecting Measurement[™]

HP PROFILE INSERTION SERIES Turbine Flowmeters for Liquids and Gases

Product Bulletin HP-104F

TECHNICAL DATA SHEET

FEATURES

- Low cost.
- Low pressure drop.
- Wide flow turndown ranges for both liquids and gases.
- Outstanding accuracy.
- Applications from 4" to 72" pipe diameters. Specials upon request.
- Process connection flexibility.
- May be installed or removed from active line without stopping service.
- ◆ -20 to +400°F standard operating temperature range with Viton Seal.

THEORY OF OPERATION

The Hoffer HP Series of Insertion Turbine Flowmeters are designed for measuring liquid and gas flow in medium to large diameter pipes with accuracies inherent in the turbine flowmeter at a substantially lower price than in-line flowmeters.

Several versions are available including fixed, adjustable, bi-directional and high pressure. In addition a number of process fittings and materials of construction may be supplied to suit the demand of various applications.

SPECIFICATIONS: LIQUIDS				
Linear Flow Ranges: (Examples)	Minimum Usable Flow Ranges:			
5 to 50 FPS.	0.25 FPS with 2" Rotor.			
2 to 20 FPS.	0.5 FPS with $1\frac{1}{2}$ " Rotor.			
1 to 10 FPS.				
LINEARITY: ±1% in 10:1 Flow Turndown Ratios. Any turndown range with a minimum of 1 FPS and maximum of 50 FPS.				

GENERAL SPECIFICATIONS LIQUIDS AND GASES

	1 <u>1</u>
SPECIFICATIONS:	GASES
inear Flow Ranges: ^{Examples)}	Minimum Usable Flow Ranges:
25 to 250 FPS.	Dependent on gas density.
0 to 100 FPS.	Consult factory.


LINEARITY: ±2% in 10:1 Flow Turndown Ratios (Typical). Turndown ratio is dependent on gas density.

REPEATABILITY:	\pm .25% Standard.	MATERIALS:	Stem, housing and rotor support are 316 stainless steel. Stem guide materials - brass				
MAX. OPERATING	PRESSURE:		(standard). Standard seal is Viton, with				
	150 PSI low pressure adjustable model. 2500 PSI fixed model.** 2500 PSI high pressure adjustable model.**		others available. Rotor - nickel 200, 430 stainless steel, 17.4 stainless steel (standard).				
* * (Deper	ndent on process connection and temperature).	OUTPUT SIGNAL:	Output level - 10 mV RMS minimum.				
BEARING TYPES:	Ceramic Hybrid Ball Bearings, Tungsten Carbide and Hard Carbon Composite Sleeve Bearings.	(MAGNETIC COIL)*	•				

Li (E 2

The NPT adjustable insertion flowmeter handle is used to align the flowmeter to the proper orientation. The flowmeter stem is graduated in inches to aid in insertion depth and has a pickup coil located within the interior. The standard adjustable insertion flowmeter with a $1 \frac{1}{2}$ " rotor assembly can mount through an isolation valve allowing removal and re-positioning without interrupting the pipeline flow. This type of installation is accomplished through a hot tap technique. The insertion flowmeter with a 2" rotor can also be installed through an isolation valve. The fixed insertion flowmeter is similar to the adjustable type except a mounting flange is welded directly to the stem. This economy version may not be used for hot tap applications.

The bi-directional insertion flowmeter has the capability to detect the direction of flow by using two low drag magnetic pickup coils positioned to generate a quadrature output signal compatible with Hoffer electronic flow measurement systems. This type of installation may also be accomplished through hot tap techniques.





Proudly Distributed By

(Also available with flanged process connection).*	*NPT/High Pressure	*NPT/Low Pressure Adjustable	Fixed Flanged	Bi-Directional
Basic Model N Rotor Size (1½) (2) Blade Angle <i>For gas applic</i> Minimum Flow <i>For liquid app</i>	IVFORMATION Jumber HP-B- 2" Rotor 2" Rotor. Must use 2" for bi-directional flow (BF) option. extions only. (See Note 3 below)* v & Maximum Flow lications only. (In FPS) ection / End Fitting 2" NPT Male Pipe 2" NPT Male Pipe 2" 000# RF 316 S.S. Flange 2" 600# RF 316 S.S. Flange 3" 300# RF 316 S.S. Flange 3" 300# RF 316 S.S. Flange 3" 600# RF 316 S.S. Flange 3" 600# RF 316 S.S. Flange 3" 600# RF 316 S.S. Flange 3" 300# RF 316 S.S. Flange 3" 600# RF 316 S.S. Flange	- (_) - (_minmax) - (_) -		
(1HTM) (1ISM)	used for some clean <i>liquid applic</i> Tungsten Carbide Sleeve availab Hard Carbon Composite Sleeve a One Magnetic Coil One RF Coil One High Tempe 6" Pigtail RF Coi One High Temperature Mag Coil Intrinsically Safe Mag Coil One ISM ATEX Coil Redi-Pulse Coil (See Redi-Pulse T	le for <i>liquid applications only.</i> vailable for <i>liquid applications only.</i>		
(E2) (X-ATEX)E2 Bi-Directional (BF)	3/4" MNPT riser with E2 enclosu (See chart)** Flow Bi-Directional flow, must use 2" forward and reverse flow direction dependent on line size, height of r	Rotor and 3" end fittings. (Supplied wit	h calibration in both	**E2 EXPLOSION-PROOF/ FLAME-PROOF ENCLOSURE WITH 3/4" FNPT MOUNT AND 3/4" CABLE ENTRY RATINGS: FM: CLASS I, DIV. 1, GR. ABCD, CLASS II, DIV. 1, GR. ABCD, CLASS II, DIV. 1, GR. EFG, CLASS II, DIV. 1, GR. EFG, CLASS II, DIV. 1, GR. EFG, CLASS II, DIV. 1, CLASS I, ZONE 1, JP 66
(AL) (AH) (F) Special Featu (CE) (SP)	Fixed (Flange Only) res CE Mark Required for Europe.	nax. working pressure. Ig pressure dependent on flange rating. d in the model number, use written dese	2. 9	ATEX: EX II 2GD Ex d tD IIC, IP66/68 IEC: EX D IIC IP68 es: Dptional isolation valves are available. Standard seals are Viton, others available.
The specification of said specification	Inumber for every option not specified. IOFFEER FLOW COO 7 Kitty Hawk Lane, P. O. Box 2145, Elia 0-628-4584 252-331-1997 Ww.hofferflow.com ns contained herein are subject to chang ations should verify from the manufactur ct. Otherwise, the manufacturer assume swhich may have been changed and are	abeth City, NC 27906-2145 FAX 252-331-2886 email: info@hofferflow.com ge without notice and any user rer that the specifications are so no responsibility for the use		Slade angle determined by density/assigned by factory. "size rotor is recommended to obtain lowes low rate possible. offer Flow Controls Quality Management System Certified to ISO 9001:2015